



CITY OF FLORENCE, ALABAMA

Department of Purchasing/Public Grants
Phillip L. Stevenson, Purchasing Agent and Public Grants Administrator

AN EQUAL OPPORTUNITY EMPLOYER INVITATION TO BID IS-116

December 13, 2016

Subject: Addendum No. 1, IS-116, Install 2" Raceway, etc. at 19 locations, Florence, Alabama

Ladies/Gentlemen:

Please be advised of the following changes to Invitation-to-Bid No. IS-116:

CHANGES:

1. Place a minimum 4' x 4' x 3/4" fire rated plywood backboard.
2. Place new #6 ground wire bonded to an MGN or UFER Ground terminated to a grounding bus bar.
3. Pull string in 2" conduit with pull tape is required from the property line to the minimum point of entry. Minimum 3' sweeping radius - no right angles - no more than three 90 degree turns without a pull box. Paths longer than 300 linear feet or with two or more 90 degree turns will require a pull box. Minimum dimensions for an in-ground pull box is 17" x 30" x 24" deep or 12" x 12" x 6" deep for other applications.
5. Access at the Kennedy-Douglas Center for the Arts requires a bore under existing sidewalks.

All other terms, conditions and documents for Invitation-to-Bid No. IS-116 shall remain the same.

Sincerely,

Phillip L. Stevenson
Purchasing Agent