

Sponsor: Anerton, Fire Department

RESOLUTION

BE IT RESOLVED BY THE CITY COUNCIL OF THE CITY OF FLORENCE, ALABAMA, as follows:

SECTION 1. The attached Invoice #106358080 dated February 19, 2025 from MPE Services, LLC, for labor and materials to make emergency repairs on the HVAC system at Fire Station #2 in the amount of \$1,985.69, is hereby approved, ratified and confirmed.

SECTION 2. The proper officials of the City are authorized to pay said invoice.

ADOPTED this _____ day of _____, 2025.

CITY COUNCIL

APPROVED this _____ day of _____, 2025.

MAYOR

ADOPTED & APPROVED this _____ day of _____, 2025.

CITY CLERK-TREASURER



MPE Services
 3311 County Rd 47
 Florence, AL 35630
 256-766-9439
 AL Cert# 22283
 Heating/Cooling, Plumbing, Electrical
 One Call Does It All!

Invoice 106358080
 Invoice Date 2/19/2025
 Completed Date 2/19/2025
 Payment Term Net 30
 Due Date 3/21/2025

Billing Address
 Florence Fire Dept
 402 South Wood Avenue
 Florence, AL 35630 USA

Job Address
 Florence Fire Dept:Station 2
 3722 Florence Boulevard
 Florence, AL 35634 USA

Description of work

Returned and checked on the other heater in the building and found that it had a bad motor on it. Waiting to hear back from parts house on motor. Once I know more I will contact Greg. The motor is \$682.50 and would have to be ordered. It will take approximately 3-5 days to arrive. Spoke with Greg and he gave me the go ahead to order. Ordered motor from RE Michael.

Returned for the heater that needed a pilot assembly. I replaced the assembly and tested operation. The heater would come on and run and shut off before reaching temp. Checked over system and found that it now had a bad gas valve.

Returned and replaced the blower motor for the taller heater and tested operation, and the system was operating normally and heating upon departure. We are still waiting for the gas valve for the shorter unit to get it up and running

Returned and replaced the gas valve on the shorter unit. Tested the heater's operation and it was functioning properly. Upon departure both heaters were running and heating normally.

Please note - technician broke a part (nut) during first return visit. That hour was not charged for. The replacement part was also not charged to customer.

Service #	Description	Quantity	Your Price	Total
1st Hour Standard Service C	1st Hour Standard Service Charge - This includes any diagnostic testing, inspection and labor for the first hour.	1.00	\$155.00	\$155.00
102 HVAC Labor Commercial	HVAC Labor Commercial	3.00	\$105.00	\$315.00
Misc Material	Pilot assembly Blower motor Gas valve	1.00	\$1,515.69	\$1,515.69

Sub-Total \$1,985.69
Tax \$0.00
Total \$1,985.69
Payment \$0.00
Balance Due \$1,985.69

Thank you for trusting MPE Services for your repairs.

For your convenience we accept Visa, Master Card, Discover and American Express for an additional 3.5% fee. We also accept a check or cash. Any returned checks will be charged a \$35.00 fee.

Thank you for your business!

I have the authority to order the above work as outlined herein. It is agreed that the Seller will retain Title to any equipment or materials furnished until final and complete payment is made. If settlement is not made as agreed, the Seller shall have the right to remove same and the Seller will be held harmless for any damages resulting from the removal thereof. Any materials not provided by MPE Services will carry no warranty.